



Amended Gasoline Dispensing Facility Regulations

As of **July 22, 2022**, the Allegheny County Health Department amended its regulations concerning control of VOC emissions at gasoline dispensing facilities (GDFs). For the full updated regulations, please see [Article XXI, Sections 2105.13.e, and 2105.14](#) (excerpted ACHD regulations). Article XXI incorporates by reference the regulations of the Pennsylvania Department of Environmental Protection [25 Pa. Code § 129.61a](#) and [25 Pa. Code § 129.82a](#).

This amendment requires the removal of all Stage II Vacuum Assist vapor recovery systems. All Stage II Vacuum Assist vapor recovery systems shall be decommissioned **on or before December 31, 2022**.

Owners/Operators of GDFs must submit a [decommissioning notification form](#) to ACHD Air Quality at AQreports@alleghenycounty.us.

Additionally, this amendment requires that all GDFs, with a monthly throughput of over 10,000 gallons of gasoline, conduct the following vapor recovery test procedures on an annual basis:

- CARB TP 201.1E - “Leak Rate and Cracking Pressure/Vacuum Vent Valves”
- CARB TP 201.3 - “Determination of 2-inch WC Static Pressure Performance of Vapor Recovery Systems of Dispensing Facilities”
- CARB TP-201.3C - “Determination of Vapor Piping Connections to Underground Gasoline Storage Tanks - “Tie-Tank Test)”
- CARB TP-201.1B - “Static Torque of Rotatable Phase I Adaptors” *ONLY if UST is equipped with a rotatable adaptor*

ALLEGHENY COUNTY HEALTH DEPARTMENT

AIR QUALITY PROGRAM • 301 39TH ST, BLDG. #7 • PITTSBURGH, PA 15201-1811
PHONE (412) 687-ACHD (2243)
WWW.ALLEGHENYCOUNTY.US/AIR