



# Allegheny County Health Department Swimming Pool Operational Log



**INDOOR POOLS MUST BE TESTED AT LEAST EVERY 6 HOURS DURING USE  
OUTDOOR POOLS MUST BE TESTED AT LEAST EVERY 2 HOURS DURING USE**

Pool Name \_\_\_\_\_

Registered Manager \_\_\_\_\_

Free Chlorine must be 1.0 – 5.0 ppm  
Free Bromine must be 2.0 – 10.0 ppm

Combined chlorine  $\leq$  0.2 ppm  
Cyanuric Acid  $\leq$  50 ppm

Date	Time	pH		Free Chlorine /Bromine		Total Chlorine Only		Combined Chlorine Only		Cyanuric Acid <small>(recorded weekly)</small>	Tested By
		Shallow	Deep	Shallow	Deep	Shallow	Deep	Shallow	Deep		

Date	Time	pH		Free Chlorine /Bromine		Total Chlorine Only		Combined Chlorine Only		Cyanuric Acid <small>(recorded weekly)</small>	Tested By
		Shallow	Deep	Shallow	Deep	Shallow	Deep	Shallow	Deep		