

Swimming Pool Operational Log



INDOOR POOLS MUST BE TESTED AT LEAST EVERY 6 HOURS DURING USE OUTDOOR POOLS MUST BE TESTED AT LEAST EVERY 2 HOURS DURING USE

Pool	Registered				
Name	Manager				
Free Chlorine must be 1.0 – 5.0 ppm	Combined chlorine <= 0.2 ppm				
Free Bromine must be 2.0 – 10.0 ppm	Cyanuric Acid <= 50 ppm				

Date	Time	рН		Free Chlorine/Bromine		Combined Chlorine Only		Cyanuric Acid (recorded	Tested By
		Shallow	Deep	Shallow	Deep	Shallow	Deep	weekly)	_

Date Time	Time	рН		Free Chlorine/Bromine		Combined Chlorine Only		Cyanuric Acid (recorded	Tested By
		Shallow	Deep	Shallow	Deep	Shallow	Deep	(recorded weekly)	•
		+							
		1							
		1							
		1							
		1							