

Westmoreland Affordable Plumbing, Heating & Cooling

41 Cherry Lane
North Huntingdon, PA 15642

Office (724)864-0188
Fax (724)864-0187

waplumbing@gmail.com

May 9, 2019

County of Allegheny
542 Fourth Avenue
Pittsburgh, PA 15219

RE: 1542 Bakerstown Road
Frazer Township

To whom it may concern:

I am writing this letter to request an Appeal Hearing pursuant to a letter I received from Ivo Miller stating that Westmoreland Affordable Plumbing, Heating & Cooling was issued a consent penalty in the amount of \$6,000.00.

We have made several attempts to contact the customer via phone and written correspondence to correct the work and have received no response from her.

We did file a plan for the underground work performed on the inside and had an inspection. However, we did not schedule a final plan.

Therefore, we are requesting an Appeal Hearing at this time. Thank you for your attention to this matter.

Sincerely,



John Morgan
Owner

JOHN
724-685-1713

ALLEGHENY COUNTY HEALTH DEPARTMENT
PLUMBING INSPECTION REPORT

FILED

COMPLAINT # _____ PLAN # _____

PROPERTY ADDRESS: 1542 BAKERSTOWN RD TARENTUM 54035
NUMBER STREET MUNICIPALITY CIT

PLUMBERS NAME: WESTMORLAND JOHN MAKOPY
LAST FIRST OWNER

TYPE OF BUILDING: SINGLE FAMILY (X) MULTI-FAMILY () COMMERCIAL ()

TYPE OF VISIT: INITIAL INSPECTION (X) REINSPECTION () SUBSEQUENT INSPECTION ()

TYPE OF TEST: AIR () WATER (X) OTHER ()

TIME OF INSPECTION FROM: _____ TO: _____

TYPE OF INSPECTION

STORM DRAIN () BUILDING DRAIN (X) WATER SERVICE () FINAL ()

STORM SEWER () ROUGH ABOVE GROUND () WATER HEATER ()

BUILDING SEWER () WATER DISTRIBUTION () INDIRECT WASTE () OTHER ()
(Partial Rough, Partial House Drain, Etc.)

PLUMBING INSPECTOR: John Westmorland DATE OF INSPECTION 4-4-17

ACCEPTED BY: [Signature] TITLE: JP H.P.# 3353

LOCATION IN BUILDING & COMMENTS: BUILDING AREA

- INSTALLED TEST TEE INTO 4" PVC ON BS SIDE AND
 1" TC ON AD SIDE - ORIGINAL PIPING

- INSTALLED 4" PVC WYE INTO FLOOR 4" TC PD

1- FD

1- 2" SINK FOR LT (NTO)

1- [unclear] (NTO)

1- SHOWER (NEW FIBERGLASS PAN TO BE INSTALLED) 1 1/2" [unclear]

WATER TESTED

NO LEAKS FOUND

I had to write over because copy wasn't clear

\$247.28 - 4/3/2017 - 9000

\$247.28 - 4/3/2017 - 9000

Taxes ✓

WESTMORELAND AFFORDABLE PLUMBING
41 CHERRY LANE
N. HUNTINGDON, PA 15642
PH 724-554-0188

DATE 4/4/17

PAY TO THE ORDER OF Treasurer of Allegheny County \$ 100.00
One Hundred and 00/100 DOLLARS

for MaKobon Solo Prevention

J. J. Jones

3761

9006

60386/433

004006 *043306855* 0001288026*

20170410 003000876011 00100064001

PAID TO THE ORDER OF
ALLEGHENY COUNTY TREASURER
HEALTH SERVICES CENTER
100 UNIVERSITY CITY CENTER
PITTSBURGH, PA 15222

\$100.00 - 4/11/2017 - 9006

\$100.00 - 4/11/2017 - 9006

Phone 11